



LABORATORY TEST REPORT

Issued To:**Legoplast Plastic Manufacturing L.L.C**

PO Box:566481

Jebel Ali Industrial Area,

Dubai, United Arab Emirates.

Report No : R2-260113-04

Report Date : 20-01-2026

Request No : Q2-260113-02

Introduction: Further to the request received from **Legoplast Plastic Manufacturing L.L.C.** dated 13th January 2026, the sample of clip spacer was tested, and the results are as follows.

Sample Received Date : 13/01/2026
Date Tested : 19/01/2026
Tested By : 048
Test Method : TH-IP-AD-002

General Information

Sample Number	Sample Description	Received
S2-260113-04	Clip spacer (40mm)	13/01/2026

Test Results

Specimen No.	Load Test		
	Maximum Load (kN)	Maximum Load (kg)	Observation
1.	3.10	316.11	Sample deformed


Remark: Test pictures are given in Annex A.

**Signed for and on behalf of Testhub Laboratories LLC****Salman Faris T****Laboratory Supervisor / Advanced Material Department**

This report shall not be reproduced, unless in its entirety, without written approval from Testhub Laboratories. The results relate only to the material or product analyzed. The information's supplied by the customer can affect the validity of result.

ANNEX A

Sample pictures



End of Report

